



## Certified Product Listing

**For:**

Drinking Water System Components – Health Effects

**Company:**

Alchemy Spetec, LLC  
4508 Bibb Blvd  
Suite B-5  
Tucker, GA 30084, United States

**Plant Location:**

Tucker, GA, United States

**Standards:**

NSF/ANSI/CAN 61 - 2020

**Certificate:**

Issued Date: 09/19/2018

**Material/Product:**

Spetec PUR GT500 - Single Component, Low Viscosity, Flexible Hydrophilic Polyurethane Foam Injection Resin

**Contact Temperature:**

23 ± 2°C

**Models:**

Spetec PUR GT500



## Material Characteristics:

Minimum tank size (gallons): 10000

Maximum tank surface area/volume ratio (sq in/L): 2.6

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): No

Final cure time: 24 hrs at 23 °C

Mix ratio: 2:1 by weight

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

Additional comments:

Maximum surface area in contact with water shall not exceed more than 1% of the total surface area.